




Status of the Liquid Scintillator for JUNO



Xin Ling (lingxin@ihep.ac.cn) on behalf of JUNO collaboration

1 The Juno Experiment

- The Jiangmen Underground Neutrino Observatory (JUNO) is a 20 kt liquid scintillator (LS) detector for studies of various neutrino physics topics. The level of radioactivity background is an essential factor for the sensitivities.
- Determine mass ordering by $3\%/\sqrt{E}$ with 3σ in 6 yrs data taking. Rich physics programs in solar, supernova, atmospheric, geo-neutrinos, proton decay, exotic searches.





2 Liquid Scintillator for Juno

Features:

- 20 kton, long term stability;
- LS attenuation length (A.L.) >20 m @ 430nm;
- Light yield: 1665 p.e./MeV;
- $^{238}\text{U}, ^{232}\text{Th} < 1 \times 10^{-15}$ g/g (Min), $< 1 \times 10^{-17}$ g/g (Max)
- Recipe: LAB + 2.5 g/L PPO + 3 mg/L bis-MSB
- QA/QC: ICP-MS (1e-15 g/g for LS; 1e-16 g/g for UPW), NAA, customized devices (A.L, Rn, Ra), Spectral analyzer, particle counting, OSIRIS

Purification system

- 5 purification sub-systems + 1 QC system + 3 auxiliary system
- 7 m³/h for filling 6 month
- All LS plants were installed and under commissioning



3 Requirements of LS Plants construction

Material requirement for LS plant

- Material of tank or pipe: SS304L or SS316L (Electro Polishing and low background).
- Material of O ring and other parts: Viton A or PTFE.

Cleanness and processing technology requirements

- Residual dust on the surface after cleaning should be $< 0.1 \text{ mg/m}^2$, which will lead to 0.08g dust and 10^{-16} g/g U238/Th232 contamination in LS.
- Stainless steel inner surface roughness requirement $Ra \leq 0.4 \mu\text{m}$.
- Welding: Orbital welding
- The final precision cleaning particle cleanliness level in rinsing water needs to be reached JUNO 50 level



Cleaning Quality Check

- Resistivity test for clean water
- PH test
- Visual inspection
- White cloth inspection
- Ultraviolet light
- Endoscopic inspection
- Blue point test
- Surface roughness test $Ra \leq 0.4 \mu\text{m}$
- Particle counter test in washed water Level 50
- Absorption spectroscopy
- ICP-MS measure the U/Th in washed water, residual particle content U/Th < 0.1ppt

JUNO 50 level for rinsing water.

Cleanliness level	Particle Size. μm	Count per liter
50	5	1660
50	15	250
50	25	73
50	50	10

Orbital welding sample



4 Alumina Filtration Plant

Goal: Removes optical impurities and increases the attenuation length of LAB

Principle: Al_2O_3 powder retains optical contaminants and enhances the LAB transparency when LAB pumped through it

Status:

- Fully commissioned
- Successful removal of optical contaminants in the range 360-400 nm, up to 20 BV.
- A.L.: raw LAB from ~21 m to >23.5 m after AFP
- No extra $^{238}\text{U}, ^{232}\text{Th}$ contamination introduced



AFP parameters	
N° columns	8 (7+1)
Height	2.8 m
Diameter	0.6 m
Bed volume (BV)	0.5 m ³
Flow rate / col.	1 m ³ /h (2 BV/h)
Filters	220 & 50 nm

5 Distillation Plant

Goal: Removes heavy metals ($^{238}\text{U}, ^{232}\text{Th}, ^{40}\text{K}$) from LAB and further improves the optical properties

Principle: Fractional distillation of LAB in partial vacuum, inside a column with 6 sieve trays and 30% internal reflux; only the purest vapours are extracted from the top. High-boiling contaminants accumulate in the un-evaporated liquid phase to be discharged.

Status:

- Fully commissioned
- absorption spectra of purified LAB meet expectation.
- A.L. measurement result of purified LAB is about 22m.

U: <0.28ppq, **Th:** <0.22ppq



Distillation plant parameters	
N° trays	6
Height	7 m
Temperature	210-220 °C
Pressure	5 mbar
Internal reflux	~30%; max 50%
Bottom discharge	max 100 L/h

6 Mixing Plant

Goal: Removes ^{238}U and ^{232}Th from PPO and bis-MSB and dilute and dissolve into LAB to produce LS.

Principle: PPO and bis-MSB are added in high concentrations (105 g/L and 126 mg/L) to produce the Master Solution, then washed with HNO_3 and rinsed twice with water. Finally, diluted with LAB to obtain the LS

Recipe: (2.5 g/L and 3 mg/L).

1 MS batch/day (420 kg PPO + 504 g bis-MSB + 4 m³ L)

Status:

- Fully commissioned
- $^{238}\text{U}, ^{232}\text{Th}$ reduced by both acid washing (1-2 orders) and filtering (1 order).

U: <0.30ppq, **Th:** < 0.24ppq



Mixing plant parameters	
Master Solutes	105 g/L PPO
Dissolving T	126 mg/L bis-MSB
Acid washing	40°C
N° acid washing	40°C with 5% HNO_3
N° water washing	1 time 1:2 (2 m ³ acid)
N° water washing	2 times, 1:1

7 Water Extraction plant

Goal: Removes polar contaminants and metal ions with $^{238}\text{U}, ^{232}\text{Th}$ and ^{40}K from LS

Principle: Use of high-purity water to clean the liquid scintillator and remove radioactive metal ions from LS.

Status:

- Fully commissioned
- Water content <200 ppm after filters
- A.L. and absorption spectra OK
- Extraction eff is 50%~70% @ ~1ppq level

U: <0.30ppq, **Th:** < 0.24ppq



Extraction tower parameters	
Water-LS ratio	1:3
Height	13 m
N° turbines	30
Temperature	Up to 70°C
Rotation speed	25-60 r/min

8 Gas Stripping Plant

Goal: Removes gaseous impurities: ^{222}Rn , ^{85}Kr , ^{39}Ar and O_2 (oxidation, photon quenching)

Principle: Gaseous impurities in the LS are transferred to the stripping gas (high purity N_2) by desorption mechanisms.

Status:

- Fully commissioned
- Good H_2O removal efficiency: 154 ppm 20 ppm
- Excellent particle counting (no particles $\geq 0.3 \mu\text{m}$)

U: <0.30ppq, **Th:** < 0.24ppq



Stripping column parameters	
Packing	Pall Rings, 13mm
Height	9 m
Diameter	500 mm
Temperature	70°C
Pressure	250 mbar
N_2 flow rate	15 Nm ³ /h

9 OSIRIS system


Goal: A 20-t detector to monitor radiopurity of LS before and during filling to the central detector

Principle:

- Few days: U/Th (Bi-Po) ~ 1×10^{-15} g/g (reactor baseline case)
- 2~3 weeks: U/Th (Bi-Po) ~ 1×10^{-17} g/g (solar ideal case)
- Other radiopurity can also be measured: $^{14}\text{C}, ^{210}\text{Po}$ and ^{85}Kr

Status:

- Fully commissioned



10 HPN

Principle: The HPN plant uses activated carbon to adsorb radon at low temperature to purify nitrogen

Status:

The commissioning result (after 10 days running):

- Radon concentration: $5.5 \pm 0.6 \text{ uBq/m}^3 < 10 \text{ uBq/m}^3$.
- Krypton concentration: 18.5 ppt < 50 ppt.
- Argon concentration: 18 ppt < 50 ppt



11 UPW

Goal: Ultra pure and low radioactivity water for Water Extraction: U&Th < 1×10^{-16} g/g; Rn < 1 mBq/m^3 ;

UPW flow rate	2.5 m ³ /h
Particle	<200 @ >0.05 μm
Radon level	<1 mBq/m ³
Radium level	<10 $\mu\text{Bq/m}^3$
U & Th	< 2×10^{-16} g/g

